



September 19, 2025

To: All Plan Holders

From: Jeff van den Eikhof, PE
City Engineer

RE: 303 Obispo Site Improvements – EV/Bus Charging Facility Project

ADDENDUM NO. 3

NOTICE TO ALL CONTRACTORS SUBMITTING BIDS AND TO ALL PLANHOLDERS:

You are hereby notified of the following changes, clarifications or modifications to the contract documents. This addendum shall supersede the original contract documents and subsequent addenda. Wherein this addendum contradicts the original contract documents and previous addenda, this addendum shall take precedence. All other conditions shall remain unchanged. The change specified below shall become a legal part of the original contract documents.

A. CHANGES AND/OR CLARIFICATIONS TO THE BID DOCUMENTS AND PLANS

1. Gates

The detail on Sheet C-3.1 of the plans is incorrect. The correct gate for the project is a cantilevered slide gate, as outlined in Section 323113, Chain Link Fences and Gates, of the Technical Specifications.

2. Gate Operator

Refer to Section 323111 Gate Operators Part 2.2A(8) Accessories:

- e. Internet gateway – For future connectivity. The contractor is not responsible for the installation of the internet connection.
- f. Smart video intercom - Deleted.
- h. Heater kit - Deleted.

Each gate must have exit loop detectors. No card reader or keypad is required for exit.

Provide four (4) remotes.

Remove the existing entry keypad and install a new entry keypad. Entry is only allowed at the south entrance. Both gates will allow exit.

Contractors shall note the acknowledgment of this addendum on page 4 of the Bid Documents (Bid Schedule).

The Bid Package can be found online at <https://cityofguadalupe.org>. On the Home page, scroll down to Bid Packages and follow the link.

Sincerely,
Jeff van den Eikhof, PE
City Engineer